

No. FSL/2023-2024/37
GOVERNMENT OF MIZORAM
FIRE & EMERGENCY SERVICES
LUNGLEI FIRE STATION

Dated Lunglei 25th May 2023.

NO OBJECTION CERTIFICATE (PROVISIONAL)

EKLAVYA MODEL RESIDENTIAL SCHOOL Building located at Pukpui, Lunglei had been inspected in respect of the implementation of Fire Prevention arrangement and the undersigned has no objection in its occupation/utilization for Educational building, subject to the installation of the following Fire Fighting arrangements as per the provision of Part IV of NBC, 2016 as mentioned below.

1. Fire Extinguisher ABC/DCP 6 kg – 15 Nos
(15 Nos already installed)
2. Miniature Circuit Breaker (MCB) to be installed at every Floor of the building.

This Provisional NOC is valid for 2(two) years which may be renewed for another two years on receipt of proper application indicating the reason for its renewal. Final NOC will be issued after satisfactory inspection report about the installation of the above Firefighting arrangements is received.



T. Lalchandama 25/25/23
(T. LALCHHANDAMA)
Station officer,
Fire & Emergency Services,
Lunglei Fire Station

Memo No: No. FSL/2023-2024/37

Dated Lunglei, the 25th May 2023

Copy to: Director, Fire & Emergency Services
Mizoram, Aizawl.

(T. LALCHHANDAMA)
Station officer,
Fire & Emergency Services,
Lunglei Fire Station